## **FECAL INCIDENTS** CLOSE POOL, **DIARRHEA?** CLOSE POOL NO CALL HEALTH DISTRICT REMOVE ALL VISIBLE POOL DRAINABLE? FECAL MATTER CHLORINE LEVEL DRAIN POOL 1 PPM TO 3 PPM CHECK CHLORINE OR HIGHER **LEVELS** REMOVE ALL VISIBLE REMOVE ALL VISIBLE FECAL MATTER FECAL MATTER SHOCK POOL TO BRUSH EXTERNAL POOL 10 PPM MINIMUM SURFACES WITH 100 PPM RUN SYSTEM FOR CHLORINE SANITIZING RAISE CHLORINE LEVEL 2 HOURS SOLUTION IF CONTAMINATED TO 3 PPM OR HIGHER BRUSH SIDES, BOTTOM, AND DECK IF CONTAMINATED WITH 100 PPM OF CHLORINE CLEAN SKIMMERS, GUTTERS RINSE AND THEN FILL POOL RUN SYSTEM FOR 2 & STRAINERS HOURS MINIMUM RUN SYSTEM 1 TURNOVER AND UNTIL CHLORINE HAS CORRECT pH, 7.2 TO 7.8, REACHED ALLOWABLE LEVELS BACKWASH OR CLEAN ADJUST ALKILINITY, CLEAN SKIMMERS GUTTERS INCREASE CHLORINE TO **FILTERS** AND STRAINERS 1 PPM TO 5 PPM CLEAN SKIMMERS, GUTTERS AND STRAINERS OPEN POOL BACKWASH, CLEAN OR BACKWASH, CLEAN OR REPLACE FILTERS REPLACE FILTERS BACKWASH, CLEAN OR REPLACE FILTERS Warren County OPEN POOL OPEN POOL **Combined Health** OPEN POOL **District** \* Treat vomitus incidents the same as diarrheal incidents